



Declaration of Performance
N° 0128-PYRO-SAFE-CT
PYRO-SAFE CT

Date: 03.11.2014
Rev. 03
Page 1 of 1

Type of product
Cable penetration seal

Identification/lot number
PYRO-SAFE CT cable penetration seal
see inscription/delivery note

Intended use:
The cable penetration seal is used for closing openings in fire-resistant walls or floors, through which cables were passed. It is to maintain the fire resistance of the wall or floor in the region of the penetration.

Producer
svt Brandschutz Vertriebsgesellschaft mbH International
Gluesinger Strasse 86
D - 21217 Seevetal

System for assessing and verifying constancy of performance
System 1

The notified body
Materialprüfanstalt für das Bauwesen Braunschweig, code number 0761

has made the initial type test for the product and has subjected the plant and the factory production control system to an initial inspection, and will also be in charge of continued supervision, assessment and approval of factory production control.

The
Certificate of Conformity No. 0761-CPD-0294

confirms that all requirements for approval of factory production control are complied with, which are listed in

ETA 13/0821

Declared performance

Table with 3 columns: Essential characteristics, Performance, Harmonised technical specifications. Rows include Reaction to fire, Fire resistance, Emission of dangerous substances, and Durability and serviceability.

The performance of the product for which the declaration of performance is issued, is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of the named and identified manufacturer.

Signed for and on behalf of the manufacturer by:

Handwritten signature of Christian Meyer-Korte

i.V. Christian Meyer-Korte
Product and sales manager
industry & OEM

Handwritten signature of Andree Schober

i.V. Andree Schober
Head of
chemical department