



Declaration of Performance
N° 01151-PYRO-SAFE-FLAMMOPLAST-KS1
PYRO-SAFE FLAMMOTECT-A

Date: 15.01.2019
Rev. 01
Page 1 of 1

Unique identification code of the product type
PYRO-SAFE FLAMMOPLAST KS 1

Intended use:

Component of kit for use in linear joint an gap seals with the trade name "joint filling system PYRO-SAFE
Fugenabdichtung – FLAMMOPLAST"

Producer

svt Brandschutz Vertriebsgesellschaft mbH International
Gluesinger Strasse 86 • D - 21217 Seevetal • Germany

System for assessing and verifying constancy of performance
System 1

European Assessment Document
EAD 350141-00-1106

European Technical Assessment
ETA-13/0543 dated 29.05.2018

certificate of constancy of performance
0761-CPR-0351

Technical Assessment Body
Deutsches Institut für Bautechnik (DIBt), Berlin

The notified body

A) + B) Materialprüfanstalt für das Bauwesen Braunschweig, Kennnummer 0761

Declared performance

Table with 3 columns: Essential characteristics, Performance, Harmonised technical specification. Rows include Reaction to fire (Class E), Fire resistance (Maximum EI 120-H-X-B-20 bis 100, etc.), Emission of dangerous substances (no dangerous substances), and Durability and serviceability (Use category type Z1).

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above. DoP online available at www.svt.de. Signed for and on behalf of the manufacturer by:

Handwritten signature of Christian Meyer-Korte

i.V. Christian Meyer-Korte
Head of Product Management

Handwritten signature of Andree Schober

i.V. Andree Schober
Head of chemical department