



Declaration of Performance

No. 01152-PYRO-SAFE®-FLAMMOPLAST-KS3
PYRO-SAFE® FLAMMOPLAST KS 3

Date: 15.01.2019
Rev.: 01

Page 1 / 1

Unique identification code of the product type

PYRO-SAFE® FLAMMOPLAST KS 3

Intended use

Component of kit for use in linear joint an gap seals with the trade name "joint filling system PYRO-SAFE® Fugenabdichtung – FLAMMOPLAST"

Manufacturer

svt Brandschutz Vertriebsgesellschaft mbH International,
Gluesinger Strasse 86, D - 21217 Seevetal

System for assessing and verifying constancy of performance

System 1

European Assessment Document

EAD 350141-00-1106

European Technical Assessment

ETA-13/0543 vom 29.05.2018

Certificate of constancy of performance

0761-CPR-0351

Technical Assessment Body

Deutsches Institut für Bautechnik (DIBt), Berlin

The notified body

Civil Engineering Materials Testing Institute (MPA BS) in Braunschweig, code number 0761

Declared performance

Essential characteristics	Performance	Harmonised technical specifications
Reaction to fire	Class E	EN 13501-1
Fire resistance	Maximum EI 120-H-X-B-20 to 100 EI 120-V-X-B-20 to 100 or EI 120-T-X-B-20 to 100 See details ETA 13/0543	EN 13501-2
Emission of dangerous substances	no dangerous substances Use scenarios: IA 1, IA 2	ETAG 026-3 TR 034
Durability and serviceability	Use category type Z1	EAD 350141-00-1106

The performance of the product identified above is in conformity with the set of declared performances.

This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above. DoP online available at www.svt.de

Signed for and on behalf of the manufacturer by:

i.V. Christian Meyer-Korte
Head of Product Management / Private Label

i.A. Daniel Bernhardt
Technical Documentation