



Declaration of Performance

No. 01155-PYRO-SAFE®-FLAMMOTECT-A
PYRO-SAFE® FLAMMOTECT-A

Date: 25.09.2018
Rev.: 04

Page 1 / 1

Unique identification code of the product type

PYRO-SAFE® FLAMMOTECT-A

Intended use

- A) Ablative fire stopping product used in penetration seals
- B) Fire stopping product used for linear joint and gap sealing

Manufacturer

svt Brandschutz Vertriebsgesellschaft mbH International,
Gluesinger Strasse 86, D - 21217 Seevetal

System for assessing and verifying constancy of performance

A) + B) System 1

European Assessment Document

- A) ETAG 026-2:2011
- B) EAD 350141-00-1106

European Technical Assessment

- A) ETA-14/0418 dated 04.12.2014
- B) ETA-18/0237 dated 16.05.2018

Certificate of constancy of performance

- A) 0761-CPR-0426
- B) 0761-CPR-0726

Technical Assessment Body

- A) Deutsches Institut für Bautechnik (DIBt), Berlin
- B) ETA-Danmark A/S

The notified body

A) + B) Civil Engineering Materials Testing Institute (MPA BS) in Braunschweig, code number 0761

Declared performance

	Essential characteristics	Performance	Harmonised technical specifications
A) + B)	Reaction to fire	Class E	EN 13501-1
A)	Fire resistance	Class EI 30 - Class EI 240 For details check ETA-14/0418	EN 13501-2
B)		Maximum Class EI 120-H-X-B-W-00 up to 200 Class EI 120-V-X-B-W-00 up to 200 for details check ETA-18/0237	
A)	Emission of dangerous substances	No dangerous substances	ETAG 018-2
A) + B)	Durability and serviceability	Use category type X	ETAG 026-2

The performance of the product identified above is in conformity with the set of declared performances.

This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above. DoP online available at www.svt.de

Signed for and on behalf of the manufacturer by:

i.V. Christian Meyer-Korte
Head of Product Management / Private Label

i.A. Daniel Bernhardt
Technical Documentation