



Declaration of Performance

No. 0128-PYRO-SAFE®-CT
PYRO-SAFE® CT / CT ML Cable Tube

Date: 25.09.2018
Rev.: 05
Page 1 / 1

Unique identification code of the product type

PYRO-SAFE® CT / CT ML Cable Tube

Intended use

Product for cable penetration seal

Manufacturer

svt Brandschutz Vertriebsgesellschaft mbH International,
Gluesinger Strasse 86, D - 21217 Seevetal

System for assessing and verifying constancy of performance

System 1

European Assessment Document

ETAG 026-2:2011

European Technical Assessment

ETA-16/0016 dated 18.01.2016

Certificate of constancy of performance

0761-CPR-0460

Technical Assessment Body

Deutsches Institut für Bautechnik (DIBt), Berlin

The notified body

Civil Engineering Materials Testing Institute (MPA BS) in Braunschweig, code number 0761

Declared performance

Essential characteristics	Performance	Harmonised technical specifications
Reaction to fire	Classification according to appendix of ETA-16/0016	EN 13501-1
Fire resistance	Depending on the type of installation, the type of building element and the penetrating services, classes EI 30, EI 45, EI 60, EI 90, EI 120 - see ETA-16/0016	EN 13501-2
Emission of dangerous substances	no dangerous substances	ETAG 026-2
Durability and serviceability	Use category type X	EOTA TR 024

The performance of the product identified above is in conformity with the set of declared performances.

This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above. DoP online available at www.svt.de

Signed for and on behalf of the manufacturer by:

i.V. Christian Meyer-Korte
Head of Product Management / Private Label

i.A. Daniel Bernhardt
Technical Documentation