



Declaration of Performance

No. 01260000-PYRO-SAFE®-DG

PYRO-SAFE® DG

Date: 25.09.2018

Rev.: 04

Page 1 / 1

Unique identification code of the product type

PYRO-SAFE® DG, PYRO-SAFE® DG-CR, PYRO-SAFE® DG-CR BS,
PYRO-SAFE® DG-CR SK, PYRO-SAFE® DG-CRF

Intended use

Intumescent products for fire sealing and fire stopping purposes without a defined final use (IU1)

Manufacturer

svt Brandschutz Vertriebsgesellschaft mbH International,
Gluesinger Strasse 86, D - 21217 Seevetal

System for assessing and verifying constancy of performance

System 1

Harmonised technical specification

EAD 350005-00-1104

European Technical Assessment

ETA-16/0268

Certificate of constancy of performance

0761-CPR-0558

Technical Assessment Body

Deutsches Institut für Bautechnik (DIBt), Berlin

The notified body

Civil Engineering Materials Testing Institute (MPA BS) in Braunschweig, code number 0761

Declared performance

Essential characteristics	Performance	Harmonised technical specifications
Reaction to fire	-	-
PYRO-SAFE® DG (For layers of a thickness ≥ 1 mm to ≥ 2 mm on metal substrates melting point ≥ 1.000 °C and on classified substrates of class A1)	B-s1,d0	DIN EN 13501-1
PYRO-SAFE® DG-CR (Nominal thickness 0,6 mm to 2,2 mm free standing, on mineral substrates (density ≥ 800 kg/(m ³)) and on classified substrates of class A1)	C-s1,d0	
PYRO-SAFE® DG-CR BS, PYRO-SAFE® DG-CR SK, PYRO-SAFE® DG-CRF	E	
Emission of dangerous substances	no dangerous substances	ETA 16/0268
Use category	Type X, Y1, Y2, Z1, Z2	EOTA TR 024

The performance of the product identified above is in conformity with the set of declared performances.

This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above. DoP online available at www.svt.de

Signed for and on behalf of the manufacturer by:

i.V. Christian Meyer-Korte
Head of Product Management / Private Label

i.A. Daniel Bernhardt
Technical Documentation