



# Declaration of Performance

No. 01151-PYRO-SAFE®-FLAMMOPLAST-KS1  
PYRO-SAFE® FLAMMOPLAST KS 1

Date: 15.01.2019  
Rev.: 01  
Page 1 / 1

## Unique identification code of the product type

PYRO-SAFE® FLAMMOPLAST KS 1

## Intended use

Component of kit for use in linear joint an gap seals with the trade name "joint filling system  
PYRO-SAFE® Fugenabdichtung – FLAMMOPLAST"

## Manufacturer

svt Brandschutz Vertriebsgesellschaft mbH International,  
Gluesinger Strasse 86, D - 21217 Seevetal

## System for assessing and verifying constancy of performance

System 1

## European Assessment Document

EAD 350141-00-1106

## European Technical Assessment

ETA-13/0543 vom 29.05.2018

## Certificate of constancy of performance

0761-CPR-0351

## Technical Assessment Body

Deutsches Institut für Bautechnik (DIBt), Berlin

## The notified body

Civil Engineering Materials Testing Institute (MPA BS) in Braunschweig, code number 0761

## Declared performance

Essential characteristics	Performance	Harmonised technical specifications
Reaction to fire	Class E	EN 13501-1
Fire resistance	Maximum EI 120-H-X-B-20 to 100 EI 120-V-X-B-20 to 100 or EI 120-T-X-B-20 to 100 See details ETA 13/0543	EN 13501-2
Emission of dangerous substances	no dangerous substances Use scenarios: IA 1, IA 2	ETAG 026-3 TR 034
Durability and serviceability	Use category type Z1	EAD 350141-00-1106

The performance of the product identified above is in conformity with the set of declared performances.

This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above. DoP online available at [www.svt.de](http://www.svt.de)

Signed for and on behalf of the manufacturer by:

i.V. Christian Meyer-Korte  
Head of Product Management / Private Label

i.A. Daniel Bernhardt  
Technical Documentation