




Through-penetration Firestop Systems

System No. C-AJ-1666

ANSI/UL1479 (ASTM E814)	CAN / ULC S115
F Rating — 3 Hr	F Rating – 3 Hr
T Rating — 0 Hr	FT Rating – 0 Hr
	FH Rating – 3 Hr
	FTH Rating – 0 Hr



1. Floor or Wall Assembly

Lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete, min thickness of solid concrete floor or wall assembly is 4-1/2 in. (115 mm). Wall may also be constructed of any UL Classified Concrete Blocks*. Opening shall be circular or rectangular with max diameter or dimensions of 10-1/4 in. (259 mm) in concrete walls and floors.

See Concrete Blocks (CAZT) category in Fire Resistance Directory for names of manufacturers.

2. Pipes/Tubes

Single to be installed within the opening. The annular space between the pipes and the periphery of the opening to be 2 in. (50 mm). Pipes to be rigidly supported on both sides of the floor or wall assembly. The following penetrants may be used:

- A. Max 6-1/4 in. (159 mm) diameter Schedule 5 (or heavier) steel pipe.
- B. Max 6-1/4 in. (159 mm) diameter Type M (or heavier) copper tubing.

3. Firestop System

The Through-Penetration Firestop System shall consist of the following:

- A. Packing Material Nom. 2-3/8 in. (60 mm) thick mineral wool board min. 9.3 pcf (150 kg/m³) firmly packed into the opening of the floor or wall as a permanent form. Packing material to be installed flush with both surfaces of the floor or wall.
- B. Fill, Void or Cavity Material* Min. 1/16 in. (2 mm) dry film thickness to be applied inside the aperture before installation and over the full surface of the mineral wool boards, and overlapping onto the concrete by min. 3/4 in. (20 mm).

 SVT BRANDSCHUTZ VERTRIEBSGESELLSCHAFT MBH INTERNATIONAL PYRO-SAFE FLAMMOTECT A

Please contact us for further information:

Information: global@svt.de

Order: order@svt.de

^{*}Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.