


Through-penetration Firestop Systems

System No. W-J-4093

ANSI/UL1479 (ASTM E814)	CAN / ULC S115
F Rating — 3 Hr	F Rating – 3 Hr
T Rating — 3 Hr	FT Rating – 3 Hr
	FH Rating – 3 Hr
	FTH Rating – 3 Hr



1. Wall Assembly

Min 7-7/8 in. (200 mm) thick lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete or min 4-1/2 in. (115 mm) thick lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete increased in depth to min 7-7/8 in. (200 mm) around the seal by the fixing on non-combustible boards. Wall may also be constructed of any UL Classified Concrete Blocks*. Opening shall be rectangular with max dimensions of 15-3/4 in. (400 mm) by 7-7/8 in. (200 mm).

See Concrete Blocks (CAZT) in the Fire Resistance Directory for names of manufacturers.

2. Cable Tray*

Nom 11-3/4 in. (300 mm) wide by max 2-3/8 in. (60 mm) deep open-perforated or solid sheet cable tray with side rails formed of min 1/8 in. (1,5 mm) thick steel. The annular space between the cable trays and the periphery of the opening to be nom. 2 in. (50 mm). Cable trays to be rigidly supported on both sides of the wall assembly.

3. Cables

Aggregate cross-sectional area of cables in cable tray not to exceed 60 percent of the cross-sectional area of the cable tray based on a max 2-3/4 in. (68 mm) cable loading depth within the tray. Cable bundles of different types shall be separated by min. 1/4 in. (5 mm). Any combination of the following types and sizes of cables may be used:

- A. Max 3/C 185 mm diam (or smaller), copper conductor cable with PVC insulation and PVC jacket.
- B. Max 5/C No. 15 AWG (1.5 mm) diam (or smaller), copper conductor cable with EPR insulation and Rubber jacket.
- C. Max 5/C No. 15 AWG (1.5 mm) diam (or smaller), copper conductor cable with XPLE insulation and EVA jacket.
- D. Max 20/C No. 19 AWG (0.6 mm) diam (or smaller), copper conductor telecommunication cables PE jacket.
- E. Max 5/C No. 15 AWG (1.5 mm) diam (or smaller), copper conductor cable with PVC insulation and PVC jacket.

4. Firestop System

The Firestop System shall consist of the following:

- A. Fill, Void or Cavity Material* — 200 mm deep pillows to be tightly packed into the opening in the wall and around the services, flush to both faces. Different size of pillow are used to best fill the space.
SVT BRANDSCHUTZ VERTRIEBSGESELLSCHAFT MBH INTERNATIONAL — PYRO-SAFE BIO-BAG
- B. Steel Mesh Guard* — Min. 50 x 50 mm steel mesh guard to be mechanically fixed to both faces of the wall, completely covering the through penetration firestop.

*Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Please contact us for further information:

Information: global@svt.de Order: order@svt.de
+49 4105-40 90-0