




# Through-penetration Firestop Systems

## System No. W-L-2689

| ANSI/UL1479 (ASTM E814) | CAN / ULC S115    |
|-------------------------|-------------------|
| F Rating — 2 Hr         | F Rating – 2 Hr   |
| T Rating — 1 Hr         | FT Rating – 1 Hr  |
| _                       | FH Rating – 2 Hr  |
|                         | FTH Rating – 1 Hr |



#### 1. Wall Assembly

The 1 or 2 hr fire rated gypsum board/stud wall assembly shall be constructed of the materials and in the manner described in the individual U400, V400 or W400 Series Wall and Partition Design in the UL Fire Resistance Directory and shall include the following construction features:

- A. Studs (not shown in diagram) Steel studs to be min 2-3/4 in. (70 mm) wide spaced max 24 in. (610 mm) OC.
- B. Gypsum Board\* The gypsum board type, thickness, number of layers, fastener type and sheet orientation shall be as specified in the individual Wall and Partition Design in the UL Fire Resistance Directory. Max size of opening to be 3-1/4 in. (82 mm) diameter.

## 2. Pipes/ Tubes

Single to be installed within the opening. The annular space between the pipes and the periphery of the opening to be 1 in (25 mm). Pipes to be rigidly supported on both sides of the wall assembly. The following penetrants may be used:

A. Nominal 1-1/4 in (32mm) diameter, 3/16 in. (4.5 mm) wall thickness multilayer PE/AL/PE composite pipe for use in closed (process or supply) or vented (drain, waste or vent) piping systems.

### 3. Firestop System

The Firestop System shall consist of the following:

- A. Packing Material Min. 9.3 pcf (150 kg/m³) mineral wool firmly packed into the opening of the wall as a permanent form. Packing material to be installed 1 in. space to both surfaces of wall.
- B. Fill, Void or Cavity Material\* Minimum 1 in. depth on both sides of the mineral wool.
  SVT BRANDSCHUTZ VERTRIEBSGESELLSCHAFT MBH INTERNATIONAL PYRO-SAFE FLAMMOTECT A
- C. Fill, Void or Cavity Material\* 1 length of 1 layer of 1/16 in (1.5 mm) by 5 in. (125 mm) wrap positioned centrally within the depth of the seal around the pipe.
  - SVT BRANDSCHUTZ VERTRIEBSGESELLSCHAFT MBH INTERNATIONAL PYRO-SAFE DG-CR 1.5

Please contact us for further information:

■ Information: global@svt.de

Order: order@svt.de

+49 4105-40 90-0

<sup>\*</sup>Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.